

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1574:143 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: ADT Security Service, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Models ADTG1-C, ADTG1F-C, ADTG1R-C, ADTG1RF-C, ADTG1-CVM, ADTG1F-CVM, ADTG1R-CVM, and ADTG1RF-CVM electronic chime/strobe. The lights are only considered synchronized when used in conjunction with listed Model ADTG1M-RM (CSFM Listing No. 7300-1574:103) sync module, which may employ Model SIGA-CC1S (CSFM Listing No. 7300-1574:113) Auto Sync Output Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 Vdc, Vfwr
Candela: 15cd, 30cd, 75cd, 110cd selectable

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as electronic chime/strobe for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Refer to listee's Installation Instruction Manual for details.

These units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

XLF: 7125-1591:220

02-11-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

FEBRUARY 11, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager